

# WHALEN DESIGNS

DRAINFIELD DESIGNERS

May 14<sup>th</sup>, 1999

Thomas Minnick  
C/o Heritage Baptist Fellowship  
PO Box 1090  
Monroe, Wa. 98272

Tax #: 052707-2-031-0000 & 052707-1-025-0000


As per your request I have evaluated the soils found on the above referenced property to determine the feasibility of installing onsite sewage disposal systems in accordance with Snohomish Health District regulations for your proposed five lot subdivision.

The far west proposed lot already has a Snohomish Health District approved drainfield design dated January 20<sup>th</sup>, 1999 done by us for the proposed church. It is my opinion that at this time the other four proposed lots will also meet minimal Snohomish Health District standards for Low Pressure type onsite sewage disposal systems for four bedroom single family residences on each lot.

Please be aware that this opinion applies only to the conditions on the property as they presently exist. Any clearing, ditching, or significant site modifications may disturb the usable area and hence, may invalidate the opinion expressed herein. Further, this letter does not constitute nor imply official County action of any kind. The ultimate acceptability of the site can only be determined by the County Health Department.

If you require any further information, please don't hesitate to call or write me.

Sincerely



Whalen Designs  
License #D1042

SOIL LOGS FOR TAX #:

052707-2-031-0000

SL 1 0-34" LOAMY MEDIUM SANDS, 34-48"+ MEDIUM SANDS

SL 2 0-22" LMS, 22-48"+ MS

SL 3 0-60"+ LMS

SL 4 0-34" LMS, 34-52"+ MS

SL 5 0-21" LMS, 21-60"+ MS

SL 6 0-24" LMS, 24-60"+ MS

SL 7 0-24" LMS, 24-48"+ MS